

table1

Green Mark Rating	Peak Building Cooling Load (RT)	
	<500 RT	≥500RT
	Minimum Design Annual System Efficiency (kW/RT)	
Certified	0.8	0.7
Gold	0.75	0.68
GoldPLUS	0.7	0.65
Platinum	0.68	0.65